

A11106 260349

NBS
Publi-
cations

Reference

NBSIR 84-2832

Economizer Algorithms for Energy Management and Control Systems

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
Center for Building Technology
Building Equipment Division
Washington, DC 20234

February 1984

Sponsored by:
Office of Building and Community Systems
U.S. Department of Energy

U.S. Navy Civil Engineering Laboratory
U.S. Department of Defense

QC

100

.U56

84-2832

1984

Ref
QC
100
U56
84-2832
1984

NBSIR 84-2832

ECONOMIZER ALGORITHMS FOR ENERGY MANAGEMENT AND CONTROL SYSTEMS

Cheol Park
George E. Kelly
James Y. Kao

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
Center for Building Technology
Building Equipment Division
Washington, DC 20234

February 1984

Sponsored by:
Office of Building and Community Systems
U.S. Department of Energy

U.S. Navy Civil Engineering Laboratory
U.S. Department of Defense



U.S. DEPARTMENT OF COMMERCE, Malcolm Baldrige, *Secretary*
NATIONAL BUREAU OF STANDARDS, Ernest Ambler, *Director*

ABSTRACT

Economizer cycles have been recognized as important energy conservation measures for building air handling systems and have been included in most Energy Management and Control Systems (EMCS). This report describes the psychrometric processes of the most commonly used economizer cycles and presents algorithms for implementing these cycles on a typical Energy Management and Control System.

Economizer cycles included in this study are dry-bulb and enthalpy types, as applied to both dry coils and sprayed coils. In addition, an enhancement to the normal enthalpy economizer cycle algorithm is presented for dual-duct or multi-zone system which takes into account differences in the costs of heating energy and cooling energy. Computer program listings of the algorithms and sample input/output data are shown in the appendices. A brief discussion of common types of air handling systems is also given to help the reader better understand the application of the algorithms presented in this report.

Key words: control strategies; cooling energy; dry-bulb economizer cycle; energy management and control system; enthalpy economizer cycle; heating energy.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	iii
LIST OF FIGURES	iv
1. INTRODUCTION	1
2. COMMON TYPES OF HVAC SYSTEMS	3
3. THE DRY-BULB ECONOMIZER CYCLE	11
4. DRY-BULB ECONOMIZER ALGORITHM	22
5. ENTHALPY ECONOMIZER CYCLE	28
6. ENTHALPY ECONOMIZER ALGORITHM	33
7. DUAL-DUCT SYSTEMS	38
8. ALGORITHM ENHANCEMENT FOR DUAL-DUCT AND MULTI-ZONE SYSTEMS	41
9. SUMMARY	45
REFERENCES	47
APPENDIX A. COMPUTER PROGRAM LISTING OF THE DRY-BULB ECONOMIZER ALGORITHM (DBE), AND SAMPLE INPUT AND OUTPUT	A-1
APPENDIX B. COMPUTER PROGRAM LISTING OF THE ENTHALPY ECONOMIZER ALGORITHM (ETC1), AND SAMPLE INPUT AND OUTPUT	B-1
APPENDIX C. DERIVATION OF THE DIMENSIONLESS FACTOR, λ	C-1
APPENDIX D. COMPUTER PROGRAM LISTING OF THE ENTHALPY ECONOMIZER ALGORITHM WITH ENHANCEMENT (ETC2), AND SAMPLE INPUT AND OUTPUT	D-1

LIST OF FIGURES

	Page
Figure 1. Single-zone air handling unit	4
Figure 2. Single-zone air handling unit with reheat system	6
Figure 3. Single-zone air handling unit with sprayed coil	7
Figure 4. Variable air volume (VAV) system	8
Figure 5. Dual duct system	10
Figure 6. Psychrometric chart of dry-bulb economizer cycle for systems not using sprayed coils or air washers	12
Figure 7. Operation of a dry-bulb economizer cycle on a single-zone air handling unit (refer to figures 1 and 6)	15
Figure 8. Operation of a dry-bulb economizer cycle on a single-zone reheat system (refer to figures 2 and 6)	17
Figure 9. Psychrometric chart of dry-bulb economizer cycle for systems employing sprayed coils or air washers	18
Figure 10. Operation of a dry-bulb economizer cycle on an air handling system with sprayed coils or air washers (refer to figures 3 and 9)	20
Figure 11. Logic flow diagram of dry-bulb economizer cycle	26
Figure 12. Psychrometric chart of enthalpy economizer cycle for systems which do not employ sprayed cooling coils or air washers	30
Figure 13. Psychrometric chart of enthalpy economizer cycle for systems with sprayed cooling coils or air washers	31
Figure 14. Logic flow diagram of the enthalpy economizer cycle	36

	<u>Page</u>
Figure 15. Psychrometric charts of the dual-duct system without sprayed coil or air washer	40
Figure 16. Logic flow diagram of the enhancement routine for dual-duct and multizone systems	43

1. INTRODUCTION

Rising energy costs, accompanied by decreasing prices for computers and microprocessors, have resulted in a rapid increase in the use of Energy Management and Control Systems (EMCS) in new and existing buildings. With the proper application algorithms, these EMCS are capable of implementing building control strategies which minimize the use of heating and air conditioning equipment to save appreciable amounts of energy. One such control strategy which is commonly found on today's EMCS is the use of outdoor air for cooling a building's interior when outdoor temperature and humidity conditions permit. Such a strategy is usually referred to as an economizer cycle.*

There are two basic types of economizer cycles. A dry-bulb economizer, which is the simpler of the two, utilizes the outdoor and return air dry-bulb temperatures to position the outdoor, return, and relief air dampers. An enthalpy economizer performs the same functions using the enthalpies of the outdoor and return air. The latter has been shown to save more energy [1,2,3], but requires the installation of additional sensors to measure the relative humidities or dew point temperatures of the outdoor and return air. These sensors require frequent maintenance and calibration to prevent measurement errors which can lead to a significant increase in building energy consumption [4] through the improper use of outdoor air for cooling.

*The phrase "economizer cycle" is misleading since there is really no thermodynamic "cycle" involved. However, this terminology has been commonly used in the literature in the past and it is adopted in this paper to avoid additional confusion.

This report describes both the dry-bulb and enthalpy economizer cycles and presents algorithms for implementing them on a typical Energy Management and Control System. In addition, an enhancement to the enthalpy economizer is presented for dual-duct systems which takes into account the relative costs of heating and cooling the air supplied to the conditioned space.

Computer programs, written in Fortran 77, are presented in the appendices for the two economizer algorithms, and for the enhancement covering dual-duct systems, with calling routines that can be used to check the operation of the economizer programs. Sample input data and resulting output are also included. It should be pointed out, however, that these programs do not contain software for reading sensors, actuating the outdoor, return, and relief air damper motors, or positioning these dampers so as to obtain the desired mixed air temperature, since these functions are typically system dependent.

In addition, since there are many different kinds of systems and many ways of controlling each type, it is always important to thoroughly analyze an application before implementing a new control strategy. The algorithms presented in the report, while covering most typical HVAC installations, may require some modifications before being used in the actual operation of a specific building system.

2. COMMON TYPES OF HVAC SYSTEMS

The numerous types of HVAC systems used in buildings and the various methods employed for controlling their operation have been discussed extensively elsewhere [5,6,7]. While it is beyond the scope of this report to try and review this information, it is useful to briefly discuss some of the more common systems found in commercial buildings in the United States. This will serve as background material for better understanding the algorithm presented in the following sections.

Figure 1 shows a typical single-zone air handling unit found in many small buildings [6]. This system is controlled to provide either heating or cooling, but not both at the same time. During cooling, there is no direct control of the humidity level in the conditioned space, although some indirect control can be achieved by properly selecting the cooling coil to provide the desired ratio of sensible to total cooling capacity at full load.

Two techniques are commonly employed for implementing dry-bulb economizer control on the above system [1]. The first utilizes an outside, return, and relief air damper controller to regulate the mixed air temperature to a given set point. The second sequences the dampers and cooling coil flow rate control valve so that the cooling coil discharge controller regulates the damper position before the cooling coil valve opens. Although the former is easier to implement with pneumatic controls, the latter is slightly more




Figure 1. Single-zone air handling unit

general in that it assures that there is no conflict between control of the cooling coil valve and control of the dampers. In addition, it is capable of providing proper control for both dry coil and sprayed coil systems. Because of these features, the second control technique (i.e., the one utilizing the cooling coil discharge temperature) was selected as the basis of the economizer algorithms presented in this report.

In order to limit the maximum relative humidity in a conditioned space [6], a HVAC system designer will often interchange the relative position of the cooling and heating coils in the system discussed above. This results in the single-zone reheat system shown in figure 2. If more than one zone is involved, the single heating coil can be replaced by reheat coils or induction reheat units in each zone.

If tighter humidity control in the conditioned space is desired, a designer will often use a sprayed cooling coil or even an air washer in place of a cooling coil [6]. The former system is shown in figure 3. Again, the single reheat coil in these figures can be replaced by multiple reheat coils or induction reheat units in each of the different zones.

Another system that is enjoying immense popularity these days because of high energy costs is the Variable Air Volume (VAV) system shown in figure 4 [6,8]. The rate of air flow may be controlled by a fan inlet (vortex) damper, a fan discharge damper, mechanical or electrical fan speed control, variable volume boxes in each zone, or some combination of these.




Figure 2. Single-zone air handling unit with reheat system




Figure 3. Single-zone air handling unit with sprayed coil




Figure 4. Variable air volume (VAV) system

Applications involving multiple zones are also handled using dual-duct and multi-zone systems to provide conditioned air to the occupied spaces in a building [6]. Both of these systems mix chilled and heated air to obtain the desired supply air conditions. The only difference is that the dual-duct system, shown in figure 5, mixes the cold and hot air at each zone, while the multi-zone system mixes it at the air handling unit and then ducts the mixed air to the zone.




Figure 5. Dual-duct system

3. THE DRY-BULB ECONOMIZER CYCLE

Dry bulb economizer cycles employing outdoor air for "free cooling" have become a common feature on air handling systems. For systems not using sprayed cooling coils or air washers, the basic dry bulb economizer cycle can be described using the sketch of the single air handling unit in figure 1 and the psychrometric chart shown in figure 6.

When the outdoor air temperature is above a changeover temperature, T_{CO} , and in region Ib in figure 6, it is always desirable to minimize the amount of outdoor air used because the enthalpy of the outside air will be greater than the enthalpy of the return air. In region Ia, the enthalpy of the outside air is less than the enthalpy of the return air, and, under certain conditions, there could be some advantage in using the maximum amount of outdoor air. However, to utilize outdoor conditions in this entire region requires measurement of the thermodynamic states of the outdoor air and return air. These measurements are, however, not available since if they were, an enthalpy economizer cycle would be used. For this reason, the outdoor and relief air dampers should be at their minimum open position and the return air damper (see figure 1) at its maximum open position whenever the outdoor air is in either Region Ia or Ib. These damper positions should also be set to satisfy the minimum fresh air requirements of the zone served by the air handling unit.




Figure 6. Psychrometric chart of dry-bulb economizer cycle for systems not using sprayed coils or air washers

When the outdoor air is in region IIa of figure 6, its dry-bulb temperature is greater than (or equal to) the dry-bulb set point temperature of the cooling coil discharge air, T_{CASP} , but less than the changeover temperature, T_{CO} . In this region, the maximum amount of outdoor air should be used, along with mechanical cooling to reduce the temperature of the mixed air to T_{CASP} . The changeover temperature, T_{CO} , should be selected so as to maximize the sum of the positive savings from region IIc and the negative savings (loss) from region IIb over the entire year. The latter is due to the high humidity conditions that exist when the outdoor air conditions are in this region (i.e., IIb). The value of T_{CO} varies with the climate and the typical conditions assumed for the thermodynamics state of the return air. Typical values of T_{CO} are given in reference [8] for most of the major U.S. cities.

For outdoor air dry-bulb temperatures below T_{CASP} , the cooling coil valve should be closed and the outdoor, return and relief air dampers modulated to maintain a cooling coil discharge temperature equal to T_{CASP} . Under these conditions, the outdoor and relief air dampers will be at their maximum open position when the outdoor air dry-bulb temperature is near T_{CASP} and gradually close, until they reach their minimum open positions, as the outdoor temperature continues to decrease. The return air damper operates in the opposite direction - gradually opening as the outdoor temperature falls below T_{CASP} .

For systems with preheat coils, such as the one in figure 2, the outdoor and relief air dampers go from whatever position they are in to a minimum open

position when the outdoor dry-bulb temperature drops to some minimum value, T_{MIN} . In region IV, with outdoor temperature below T_{MIN} , only the minimum amount of outside air, needed to satisfy the building's fresh air requirements, is used and the preheat coils are operated to raise the mixed air temperature to T_{CASP} . The value of T_{MIN} may be selected to correspond to that outdoor temperature which results in a mixed air temperature of T_{CASP} when the minimum amount of outside air is mixed with return air. However, this may not protect the preheat coils from freezing and, depending on the system employed, it may be necessary to select a higher value for T_{MIN} .

All of the systems shown in figures 1 through 5 are usually controlled in the manner described above when a dry-bulb economizer cycle is employed. However, there are some interesting differences in the actual operation of the systems that are worth discussing. For the single-zone air handling unit in figure 1, the outdoor and return air are mixed to obtain a temperature T_{CASP} leaving the cooling coil (with no mechanical refrigeration) when the outdoor temperature is in region III of figure 6. Maximum and minimum outdoor air, plus mechanical refrigeration, is used to maintain this same cooling coil discharge temperature when the outdoor temperature is in region II and I, respectively. Operation in these three regions is shown in figure 7. The value of T_{CASP} is selected to satisfy the space conditioning needs of the zone served. For the reheat system in figure 2, T_{CASP} is usually lower than the supply air temperature needed to cool the conditioned space. This is done to remove moisture from the air and thus limit the maximum relative humidity




Figure 7. Operation of a dry-bulb economizer cycle on a single-zone air handling unit (refer to figures 1 and 6)

allowed in the space and/or to satisfy a diversity of cooling loads among a number of zones. As a result, the air leaving the cooling coil must be reheated, either using a single reheat coil as illustrated in figure 8, or using separate coils in each of the different zones.

Figure 9 shows the psychrometric chart for a system using a sprayed coil (as shown in figure 3) or an air washer. The dry-bulb temperature measured leaving the coil or air washer is actually very close to the dew point temperature of the leaving air. Air entering the spray or washer will be cooled down along its constant enthalpy line until it is nearly saturated. Thus the various regions on the psychrometric chart for this type of system are somewhat different than those discussed above. Region III in figure 9 is bounded on the right by the constant enthalpy line passing through the saturation curve at a dew point temperature equal to T_{CASP} . Outdoor air in region III is mixed with return air so that the thermodynamic state of the mixed air falls on this constant enthalpy line. Actual control of the system is unchanged, since the mixing is done to maintain a cooling coil discharge air temperature (or air washer discharge air temperature) equal to T_{CASP} . Since T_{CASP} is usually lower than the temperature required to satisfy the sensible cooling load in order to maintain close humidity control in the conditioned space, this air will typically be reheated to the desired supply air temperature. The minimum amount of outside air is used in regions Ia and Ib for the same reasons discussed above for systems not employing sprayed coils or air washers. The changeover temperature, T_{CO} , is, however, likely to shift somewhat due to changes in the shape of regions II and III and because the energy requirements




Figure 8. Operation of a dry-bulb economizer cycle on a single-zone reheat system (refer to figures 2 and 6)




Figure 9. Psychrometric chart of dry-bulb economizer cycle for systems employing sprayed coils or air washers

to condition the supply air in these regions is different for systems employing sprayed coils or air washers. Since this changeover temperature will vary with climate and the value chosen for T_{CASP} , each system should be analyzed separately to determine the optimal value of T_{CO} . Operation of a dry-bulb economizer cycle in regions I, II, and III for systems employing sprayed coils or air washers is shown in figure 10.

The variable air volume system, shown in figure 4, behaves like either the single zone air handling unit in figure 1 or the reheat system in figure 2, depending on whether a heating coil (not shown in figure 4) is placed upstream or downstream of the cooling coil. The difference is that the variable volume system provides multi-zone control with a single supply duct by varying the quantity of air supplied to each zone. The psychrometric charts for a dry-bulb economizer cycle applied to this type of system are identical, respectively, to the ones discussed above in figures 6 and 9 for VAV systems which do not employ spray coils or air washers and for those that do.

As mentioned earlier, dual duct systems and multi-zone systems differ only in the location where hot air and cold air mixing takes place. These systems may use either non-sprayed or sprayed cooling coils. In a system using a sprayed cooling coil (or an air washer), all of the air is usually passed through the sprayed coil, and then part is reheated and mixed with the cooling air to satisfy the various zone requirements. However, the most common system configuration uses a non-sprayed cooling coil and such an arrangement (for a

- I: Min. OA + mechanical cooling
- II: Max. OA + mechanical cooling
- III: Mixed OA and RA
- IV: Min. OA + heating
- RA: Return air
- OA: Outside air
- MA: Mixed air
- SA: Supply air




Figure 10. Operation of a dry-bulb economizer cycle on an air handling system with sprayed coils or air washers (refer to figures 3 and 9)

dual-duct system) was shown in figure 5. The psychrometric charts for the typical application of dry-bulb economizer cycles to these systems are given in figures 6 and 9 for systems with non-sprayed and sprayed coils, respectively.

4. DRY-BULB ECONOMIZER ALGORITHMS

Although the presentation in the previous section on how a dry-bulb economizer cycle works tends to be somewhat complex because of the different types of coils and systems involved, the actual dry-bulb economizer algorithm is very simple. In addition, it is usually implemented on the various HVAC systems described above in almost an identical manner. The algorithm may be expressed in words as follows:

- (a) If the measured outdoor air temperature, T_{OA} , is greater than or equal to the preselected changeover temperature, T_{CO} , then the outdoor, return and relief air dampers should be positioned to admit the minimum amount of outside air to the building that is necessary to satisfy the fresh air requirements.
- (b) For HVAC systems not using sprayed coils (or air washers), the dampers should be positioned to admit the maximum amount of outdoor air when the outdoor temperature, T_{OA} , is greater than or equal to T_{CASP} but less than the changeover temperature, T_{CO} . For systems employing sprayed cooling coils (or air washers) the dampers should be positioned to admit the maximum possible outdoor air as long as T_{OA} is below T_{CO} and mechanical cooling is required to maintain the cooling coil discharge air temperature, T_{CA} , at its set point, T_{CASP} .

- (c) The outdoor, return, and relief air dampers should be positioned to mix outdoor air and return air when T_{OA} is less than T_{CASP} for systems not using sprayed coils (or air washers) or when T_{OA} is less than T_{CO} and mechanical cooling is not required to maintain T_{CA} at T_{CASP} for systems with sprayed coils (or air washers). In both cases, the mixing should be controlled so as to maintain the cooling air discharge temperature, T_{CA} , at its set point, T_{CASP} .
- (d) For systems with preheating coils, the mixed damper control should be overridden and the dampers positioned to admit the minimum amount of outdoor air when the outdoor air temperature, T_{OA} , is equal to or below some assigned value, T_{MIN} . The minimum amount of outdoor air should be that required to meet the minimum fresh air requirements of the conditioned space.

The actual sequencing of the dampers and the cooling coil valve can be accomplished in a number of ways. If pneumatic actuators are used, the dampers and coil actuators can be assigned different pressure ranges so that it is physically impossible for controlled mixing and cooling coil operation to occur at the same time. For direct digital control systems, the same thing can be accomplished by introducing a small control differential or dead zone, Δ , about the set point temperature of the cooling coil discharge air. This is to prevent excessive switching between control of the cooling coil and control of the dampers when the outside air temperature is very close to T_{CASP} . This approach is implemented by checking to see if T_{CA} is greater than or equal to

$T_{\text{CASP}} + \Delta$ before switching from mixing control of the dampers to control of the cooling coil. Likewise, T_{CA} must be less than or equal to $T_{\text{CASP}} - \Delta$, before switching from cooling coil valve control to control of the dampers for mixing purposes.

When the outside air temperature, T_{OA} is at or close to the changeover temperature, T_{CO} , the use of control differential, Δ , can minimize the frequency of switching between the outdoor air damper position to admit the maximum amount of outside air (Region II) and that to admit the minimum amount of outdoor air (Region I). This floating region associated with Δ is bounded by $T_{\text{CO}} \pm \Delta$.

Actual control of the outdoor, return, and relief air dampers when operating in the mixing mode and control of the cooling coil valve will depend upon the type of control system used. A dedicated pneumatic or electronic controller could be employed or direct digital control can be provided by the energy management and control system. It will be pointed out, however, that direct digital control of valves and dampers can be accomplished either using position algorithms which require feedback on the position of a valve or a damper, or using velocity algorithms which do not require feedback.

A logic flow diagram representing the operation of the dry-bulb economizer algorithm is shown in figure 11. The input variables to this algorithm are:

T_A measured outdoor air dry-bulb temperature
 T_{CO} specified changeover temperature (TCHG is used in the computer program)
 T_{CA} measured cooling coil discharge air dry-bulb temperature
 T_{CASP} set point value of cooling coil discharge air dry-bulb temperature
 Δ control differential (or dead zone) to minimize the switching frequency of damper or coil valve opening. For simplicity, a single control differential is used for all floating regions in the dry-bulb economizer cycle algorithm in this report.
 T_{MIN} specified outdoor air dry-bulb temperature where the minimum position of the outside air damper is reached
 SPRAY logical variable indicating type of cooling coil, SPRAY = TRUE if system uses a sprayed coil or air washer, FALSE otherwise

The output variables of the algorithm are:

CCLV logical variable indicating whether cooling coil valve is to be controlled to maintain T_{CA} equal to T_{CASP} (CCLV = TRUE) or closed (CCLV = FALSE)
 DAMPOA integer variable for controlling dampers
 = 0 for admitting minimum outdoor air
 = 1 for controlling damper to mix outdoor and return air to maintain T_{CA} equal to T_{CASP}
 = 2 for admitting maximum outdoor air




Figure 11. Logic flow diagram of dry-bulb economizer cycle

The above algorithm assumes that the building return air temperature, T_{RA} , is at or close to the set point temperature of the conditioned space. If the HVAC system has recently been started up after the end of an unoccupied period and T_{RA} is not near the desired conditioned space temperature, then this economizer algorithm should not be used or else it should be overridden or supplemented with a building warm-up or cool down control algorithm.

A computer program, DBE, for this dry-bulb algorithm, written in Fortran 77, is contained in Appendix A. A calling routine, DBEMAIN, is also presented there. Sample input and output of the program using a Sperry 1100/82 computer are provided.

5. ENTHALPY ECONOMIZER CYCLE

In an enthalpy economizer cycle, the specific enthalpy or heat content of both the outdoor air and the return air are determined. This information is then used to decide whether the minimum or maximum amount of outside air should be used or if the outside and return air should be mixed to satisfy the sensible and latent cooling requirements of the conditioned space. Since these decisions are made in real time and can dynamically account for any changes in the thermodynamic state of the outside and return air, the enthalpy economizer tends, in general, to save more energy than the dry-bulb economizer cycle [2,3]. The need for an assigned changeover temperature, T_{CO} , to account for typical outdoor and return air conditions is also eliminated.

The operation of the enthalpy economizer cycle can most easily be explained using psychrometric charts similar to the ones discussed above. Figure 12 is such a chart for a system which does not employ a sprayed cooling coil or an air washer. In region Ia of this figure, the enthalpy of the outside air is greater than that of the return air and thus the dampers should be set to admit the minimum amount of outside air required to meet the fresh air needs of the conditioned space. In region Ib, the enthalpy of the outside air is less than the return air enthalpy, but the amount of sensible cooling necessary to reduce the temperature of the outside air to the set point of the cooling coil discharge air is greater than the amount needed if return air is used. Because of this and because the majority of HVAC systems will be doing

only sensible cooling when the outside temperature is in most of region Ib, the minimum amount of outside air should be used in this region. In region II, the use of the maximum possible outside air will reduce the system's energy consumption since both the enthalpy and dry-bulb temperature of the outside air are less than the corresponding values for the return air.

When the outside temperature is in region III of figure 12, the outside and return air streams should be mixed to obtain a mixed air temperature of T_{CASP} and the cooling coil valve should be closed (i.e., no mechanical cooling is done). For HVAC systems with preheat coils, such as the one in figure 2, the outdoor and relief air dampers should be reset to their minimum open position whenever the outside air temperature falls below an assigned minimum value, T_{MIN} (Region IV).

The psychrometric chart for an enthalpy economizer cycle applied to HVAC systems using a sprayed cooling coil or air washer is shown in figure 13. As in the case of the dry-bulb economizer cycle applied to this type of system, region III is larger and extends, on the right side, to the enthalpy line passing through T_{CASP} . This is because if outside air and return air streams are mixed to obtain this enthalpy, the resulting mixed air will be cooled down to approximately T_{CASP} by means of evaporative cooling as it passes through the sprayer or air washer without mechanical cooling being done. The region corresponding to maximum outside air use, region II, is also extended, on the right, to the enthalpy line of the return air. Thus, for systems employing sprayed coils or air washers, it is desirable to use the maximum amount of




Figure 12. Psychrometric chart of enthalpy economizer cycle for systems which do not employ sprayed cooling coils or air washers




Figure 13. Psychrometric chart of enthalpy economizer cycle for systems with sprayed cooling coils or air washers

outside air whenever the outside air enthalpy is less than the enthalpy of the return air but greater than the desired enthalpy of the cooling coil discharge air.

6. ENTHALPY ECONOMIZER ALGORITHM

The enthalpy economizer may be expressed as follows:

- (a) For systems not employing sprayed coils (or air washers), the outdoor, return and relief air dampers should be positioned to admit the minimum amount of outside air (needed to meet the space's minimum fresh air requirements) when either the enthalpy or the dry-bulb temperature of the outside air is greater than or equal to the enthalpy or the dry-bulb temperature of the return air, respectively. For systems using sprayed coils or air washers, the minimum amount of outside air should be used whenever the enthalpy of the outside air is greater than or equal to the return air enthalpy.

- (b) The maximum amount of outside air should be used with systems which do not contain sprayed coils (or air washers) whenever the dry-bulb temperature of the outside air is greater than or equal to T_{CASP} and both the dry-bulb temperature and the enthalpy of the outside air is less than the dry-bulb temperature, and enthalpy of the return air, respectively. For systems containing sprayed coils (or air washers), the maximum amount of outside air should be used as long as mechanical cooling is required to maintain the cooling coil discharge air temperature, T_{CA} , at its set point, T_{CASP} , and the enthalpy of the outside air is below the enthalpy of the return air.

- (c) Controlled mixing of the outside and return air should be done when T_{OA} is less than T_{CASP} for systems not employing sprayed coils (or air washers) or when mechanical cooling is not required to maintain T_{CA} at T_{CASP} for systems with sprayed coils (or air washers). The mixing should be done to maintain the cooling air discharge temperature, T_{CA} , at its set point, T_{CASP} .
- (d) For systems with preheating coils, controlled mixing should be overridden and the dampers positioned to admit the minimum amount of outside air when the outdoor air temperature, T_{OA} , is equal to or below some assigned value T_{MIN} . The minimum amount of outside air should be that required to meet the minimum fresh air requirements of the conditioned space.

The same points, regarding sequencing and control of the dampers and cooling coil, that were discussed in the section entitled "Dry-Bulb Economizer Algorithm," also apply to the enthalpy economizer cycle. Briefly, if direct digital control is used on a system with a sprayed cooling coil (or an air washer), sequencing of the cooling coil and dampers will require the use of a small control differential or dead zone, Δ , about the set point temperature T_{CASP} to prevent excessive switching between control of the cooling coil and control of the dampers. The same Δ can also be applied to prevent excessive switching between the minimum and maximum open positions of the outdoor damper. For both sprayed coil and non-sprayed coil systems, controlled mixing of the outdoor and return air streams, as well as control of the cooling coil, may also be accomplished using dedicated pneumatic or electronic controllers.

A logic flow diagram for the enthalpy economizer algorithm described above is presented in figure 14. The input variables to this algorithm are:

T_{OA}	outdoor air dry-bulb temperature
T_{RA}	return air dry-bulb temperature
T_{CA}	measured cooling coil discharge air temperature
T_{CASP}	set point value of cooling coil discharge air dry-bulb temperature
T_{MIN}	specified outdoor air dry-bulb temperature where the minimum position of the outside air damper is reached.
Δ	control differential (or dead zone) to minimize the switching frequency of damper or coil valve opening. For simplicity, a single control differential is used for all floating regions in the dry-bulb economizer cycle algorithm in this report.
BP	measured barometric pressure
SPRAY	logic variable indicating type of cooling coil, SPRAY = TRUE, if system uses a sprayed coil or air washer, otherwise SPRAY = FALSE otherwise
METRIC	logical variable indicating whether metric or English units are used, FALSE if English units are used
DEWPT	logical variable. Set TRUE if outside and return air dew points are measured. Set FALSE if outside and return air relative humidities are measured.




Figure 14. Logic flow diagram of the enthalpy economizer cycle

In addition, the following measured data are also required:

DPOA	dew point of outside air
DPRA	dew point of return air
or	
RHOA	relative humidity of outside air
RHRA	relative humidity of return air

depending whether the value of DEWPT is set TRUE or FALSE, respectively.

Output variables are CCLV and DAMPOA, which have been described in section 4 of this report.

If the HVAC system has recently been started up after the end of an unoccupied period and T_{RA} is not near the setpoint temperature of the condition space, then the enthalpy economizer algorithm given above should not be used or should be overridden or supplemented with a building warm-up or cool down control algorithm.

A computer program, called ETC1 for this enthalpy economizer algorithm, is presented in Appendix B. A calling routine, ETC1MAIN, and a routine for calculating the required psychrometric properties of moist air (PSYCHR) [9,10] are also listed. Sample input and output are included.

7. DUAL-DUCT SYSTEMS

Dual-duct systems utilize two ducts to distribute the conditioned air to conditioned spaces. One duct delivers chilled air, and the other carries heated air at all times. In order to satisfy the thermal load requirement of the conditioned zone, the hot and cold air is mixed in proper proportion in the mixing box, which is located at each zone. The damper of the mixing box operates in response to the zone thermostat [6]. A basic dual-duct system is shown in figure 5. As briefly mentioned in section 2, dual-duct systems are similar to multi-zone systems. The difference between the two systems is the location where the cold and hot air is mixed. In the multi-zone system, air mixing takes place at the air handling unit and then the mixed air is ducted to various conditioned spaces using a single-duct. In addition, the multi-zone system has a set of cold and hot deck dampers serving for each zone. These dampers are located at the air handling unit and are controlled by each zone thermostat. Due to similarity of the two systems, only the dual-duct system is discussed in this section.

As shown in figure 5, the outside air and the return air by-pass dampers and are mixed prior to the supply fan. The supply fan delivers the supply air to the hot and cold decks respectively. In the hot deck, the air passing through the heating coil is heated, while the air passing through the cooling coil is chilled in the cold deck. Usually no mechanical cooling is needed during the heating season (winter) and no heating is required during the cooling season

(summer). The temperature of the mixed air satisfies adequately the zone requirement [6]. But at certain conditions, both heating and cooling operations are required.

Figure 15 depicts the psychrometric chart of a dual-duct system without sprayed coil or air washer. This figure shows the thermodynamic conditions of the air during the cooling season with both heating and cooling coils in operation. The mixed air (MA) temperature is slightly raised to that of the supply air (SA) due to the fan heat gain. The two air streams after the supply air fan are then chilled and heated to the conditions of CA and HA, respectively. In the mixing box, they are mixed to the conditions of zone air (ZA).

When an economizer cycle is applied to the dual-duct system, the cooling energy is reduced by the free cooling of the outside air. However, the overall energy cost of the system may be more wasteful than the system without the economizer cycle, depending on the difference in the unit costs of the cooling and the heating energy, the mass flow ratio of the cold and hot air streams, and the temperature of the hot air (HA). Therefore, an enhancement algorithm for the dual-duct system was developed and is described in the next section.




Figure 15. Psychrometric charts of the dual-duct system without sprayed coil or air washer

8. ALGORITHM ENHANCEMENT FOR DUAL-DUCT AND MULTI-ZONE SYSTEMS

The enthalpy economizer algorithm presented in section 6 assumes that the heating cost is the same as the cooling cost for the same amount of energy used. The correctness of this assumption has no effect on single-zone systems. But a more complex evaluation of the system operation is needed for the dual-duct and multi-zone systems to determine the overall energy effect of the enthalpy economizer operation. The enhancement algorithm described in this section is an optional procedure which supplements the enthalpy economizer algorithm presented previously. Application of the optional enhancement requires the input of additional information which will be described later.

As seen in figure 12, when the enthalpy economizer is employed to a single-zone system, the use of a minimum amount of outdoor air is economical if the thermodynamic state of outdoor air is in region I, and admitting the maximum amount of outdoor air is cost-saving if the psychrometric property of the outdoor air is in region II. This statement is not always true for dual-duct and multi-zone systems. The optional procedure introduces a dimensionless factor, λ , to be used to compare the energy costs of the system in these two regions. The factor λ is defined as the ratio of the total energy cost (cooling and heating) of the air-handling system with the outside air damper at the minimum opening position to that with the damper at its maximum opening position. The derivation of λ may be found in Appendix C.

In regions I and II, a decision based on the cost evaluation of λ replaces the decision made by the enthalpy algorithm described previously. If λ is greater than 1.0, the maximum amount of outside air is allowed to enter the system. Otherwise, the minimum amount of outside air is admitted. When the psychrometric condition of the outside air is in regions III and IV, no cost evaluation is performed and the algorithm described previously applies. The logic flow diagram of the enhancement routine is shown in figure 16. This cost comparison routine incorporates the enthalpy economizer algorithm, ETC1, and requires the following additional data:

COST	logical variable indicating whether cost evaluation is desired (COST = TRUE), or not (COST = FALSE).
T _{HA}	dry-bulb temperature of heating coil discharge air
X _{CA}	ratio of cooling coil air flow rate to supply air flow rate
X _{HA}	ratio of heating coil air flow rate to supply air flow rate
X _{OAMIN}	ratio of minimum outside air flow rate to supply air flow
HGTOCL	cost ratio of heating energy to cooling energy for the same amount of energy $= \frac{\$ \text{ of heating per Btu or KJ}}{\$ \text{ of cooling per Btu or KJ}}$
DPCA	dew point of cooling coil discharge air
DPHA	dew point of heating coil discharge air
or	
RHCA	relative humidity of cooling coil discharge air
RHHA	relative humidity of heating coil discharge air




Figure 16. Logic flow diagram of the enhancement routine for dual-duct system

A computer program, ETC2, of the enthalpy economizer algorithm incorporating the optional enhancement routine (HCCOST) is given in Appendix D. Sample input and output are included. When the logical value of COST is false, the program ETC2 performs the same role as the program ETC1, and the logical flow becomes identical.

9. SUMMARY

Commonly used air handling systems were briefly reviewed in this report. These systems included single-zone, reheat, variable air volume, and dual-duct types having either dry cooling coils or sprayed coils. Energy Management and Control Systems often incorporate dry-bulb or enthalpy economizer cycles in order to reduce energy consumption. In this study, the psychrometric chart of atmospheric air was divided into various regions, using the psychrometric states of the return air, cooling coil discharge air, supply air, and other pertinent parameters. Algorithms were developed for an EMCS to determine the amount of outside air to be admitted into the air handling systems for outside air conditions in the different regions and the types of coils used (dry or sprayed).

For the economizer cycles based upon measured dry-bulb temperatures, the algorithms require values of the outside air temperature, a specified changeover temperature and its control differential, the actual and setpoint temperatures of the cooling coil discharge air, a specified outdoor air temperature below which the minimum position of the outside air damper is to be used, and knowledge of the type of cooling coil (dry or sprayed). For the enthalpy economizer cycle, the changeover and outside air temperatures in the above list are replaced by the return air temperature and outside air enthalpy, respectively. In addition, the return air humidity is also required.

Since the energy savings of dual-duct and multi-zone systems are complicated by the relative costs of heating energy and cooling energy, an enhancement algorithm for these systems was also developed which utilized the relative costs of heating and cooling energies and the mass flow rates of the heating and cooling air.

Computer programs, written in Fortran 77, were presented in the appendices to assist the reader in implementing these algorithms.

REFERENCES

- [1] Shavit, G., "Enthalpy Control Systems Increased Energy Conservation," Handbook of Energy Conservation for Mechanical Systems in Buildings, edited by R. W. Roose, Van Nostrand Reinhold Co., 1978, pp. 449-460.
- [2] Parken, W.H., Kao, J.Y., and Kelly, G. E., "Strategies for Energy Conservation in Small Office Buildings," Natl. Bur. of Standards, NBSIR 82-2489, June 1982.
- [3] Kao, J.Y., Parken, W.H., and Pierce, E.T., "Strategies for Energy Conservation for a Large Retail Store," Natl. Bur. of Standards, NBSIR 82-2580, Sept. 1982.
- [4] Kao, J.Y., and Pierce, E.T., "A Study of Sensor Errors on Building Energy Consumption", 7th Energy Management and Control Soc. Conf., Salt Lake City, Utah, Nov. 14-17, 1982.
- [5] ASHRAE, System Handbook, Chapter 3, 1980.
- [6] Haines, R.W., Control Systems for Heating, Ventilating and Air Conditioning, 3rd ed., Van Nostrand Reinhold, 1983.
- [7] Croome, D.J., and Roberts, B.M., Air Conditioning and Ventilation of Buildings, 2nd ed., Vol 1, Pergamon Press, 1981.
- [8] Honeywell, Energy Conservation with Comfort, 2nd ed., 1979
- [9] Brokaw, R.S., "Calculation of Flue Losses for High-Efficiency Furnaces and Appliances," ASHRAE Journal, Jan. 1979, pp. 49-51.
- [10] ASHRAE, Fundamentals Handbook, Chapter 5, 1981.

THE
JOURNAL
OF
THE
ROYAL ANTHROPOLOGICAL INSTITUTE
VOLUME 18
PART 1
1888
LONDON
PUBLISHED BY THE INSTITUTE
21, BEDFORD SQUARE, W.C.
1888

APPENDIX A. COMPUTER PROGRAM LISTING OF THE DRY BULB ECONOMIZER
ALGORITHM (DBE), AND SAMPLE INPUT AND OUTPUT

```

Q$Q$Q$*ETC(1).DBEALL(0)
1      C *****
2      C
3      C   DBE:   Dry-bulb economizer cycle algorithm
4      C           for building air handling systems
5      C
6      C   JULY 29, 1983 C.P.
7      C
8      C -----
9      C
10     C   CCLV   Logical variable for controlling a cooling
11     C           coil valve. CCLV=T when the valve is open and CCLV=F
12     C           when it is closed.
13     C
14     C   DAMPOA Integer variable for controlling dampers.
15     C           DAMPOA = 0 for admitting minimum outdoor air
16     C           = 1 for modulating dampers
17     C           = 2 for admitting maximum outdoor air
18     C
19     C   DELTA   Temperature difference of floating zone to minimize
20     C           the switching frequency of damper or coil valve opening
21     C
22     C   SPRAY   Logical variable indicating type of cooling coil,
23     C           SPRAY = T if system uses a sprayed coil or air washer,
24     C           SPRAY = F otherwise.
25     C
26     C   TCA     Measured cooling coil discharge air dry-bulb temperature
27     C
28     C   TCASP   Set point value of cooling coil discharge air dry-bulb
29     C           temperature
30     C
31     C   TCHG    Specified changeover temperature
32     C
33     C   TMIN    Specified outside air dry bulb temperature below which
34     C           minimum outside air is admitted
35     C
36     C   TOA     Measured outdoor air dry-bulb temperature
37     C
38     C   ---     Either English or metric unit can be used.
39     C
40     C *****
41     C
42     C   SUBROUTINE DBE
43     C   LOGICAL CCLV,SPRAY
44     C   INTEGER DAMPOA
45     C   COMMON /BK1/ TOA,TCHG,TCA,TCASP,TMIN,SPRAY,DELTA
46     C   &      /BK2/ CCLV,DAMPOA
47     C
48     C   Dry-bulb economizer
49     C
50     C   Determine outdoor air damper opening and cooling coil valve
51     C   operation
52     C
53     C   IF(TOA.LE.TMIN) THEN
54     C       CCLV=.FALSE.
55     C       DAMPOA=0
56     C   ELSEIF(TOA.GE.TCHG+DELTA) THEN
57     C       CCLV=.TRUE.

```



```

58          DAMPOA=0
59      ELSEIF(TOA.LE.TCHG-DELTA) THEN
60          IF( SPRAY) THEN
61              IF(TCA.GE.TCASP+DELTA) THEN
62                  CCLV=.TRUE.
63                  DAMPOA=2
64              ELSEIF(TCA.LE.TCASP-DELTA) THEN
65                  CCLV=.FALSE.
66                  DAMPOA=1
67              ENDIF
68          ELSE
69              IF(TOA.GE.TCASP+DELTA) THEN
70                  CCLV=.TRUE.
71                  DAMPOA=2
72              ELSEIF(TOA.LE.TCASP-DELTA) THEN
73                  CCLV=.FALSE.
74                  DAMPOA=1
75              ENDIF
76          ENDIF
77      ENDIF
78      C
79      RETURN
80      END
81      C *****
82      C
83      DBEMAIN : Main program to call the dry-bulb economizer
84                algorithm for building air handling systems
85      C
86      JULY 29, 1983 C.P.
87      C
88      C *****
89      C
90      CHARACTER TITLE(2)*80
91      LOGICAL CCLV,SPRAY
92      INTEGER DAMPOA
93      COMMON /BK1/ TOA,TCHG,TCA,TCASP,TMIN,SPRAY,DELTA
94      & /BK2/ CCLV,DAMPOA
95      NAMELIST /INPUT/ SPRAY,TCHG,TCASP,TMIN,DELTA
96      & /OUTPUT/ CCLV,DAMPOA
97      OPEN(7,FILE='DBEDATA')
98      REWIND 7
99      C
100     C      Read initial input data
101     C
102     READ(7,1000) TITLE
103     READ(7,INPUT)
104     PRINT 1000,TITLE
105     PRINT INPUT
106     C
107     C      Read measured input data
108     C
109     10 IF( SPRAY) THEN
110         READ(7,*,END=999) TOA,TCA
111         PRINT 2000,TOA,TCA
112     ELSE
113         READ(7,*,END=999) TOA
114         PRINT 2000,TOA
115     ENDIF

```

```

116      C
117      C      Call the dry-bulb economizer algorithm
118      C
119      CALL DBE
120      C
121      PRINT OUTPUT
122      PRINT 3000
123      C
124      C      Damper and cooling coil valve control routines should be
125      C      called here. These routines are machine-dependent.
126      C
127      GOTO 10
128      C
129      C      Format statements
130      C
131      1000  FORMAT(A80/A80)
132      2000  FORMAT(8F10.4)
133      3000  FORMAT(1X,79('-','))
134      C
135      999   STOP
136      END

```

QSQSQS*DBEDATA(1)

```
1      INPUT DATA FOR DBE PRGOGRAM
2      DRY COIL
3      $INPUT SPRAY=F,TCHG=77,TCASP=55.,TMIN=30.0,DELTA=1.0,$END
4      95.0
5      75.0
6      67.0
7      40.0
8      80.0
9      74.0
10     50.0
11     53.0
12     55.0
13     55.5
14     55.0
15     57.0
16     55.5
17     55.0
18     54.0
19     55.0
20     50.0
```

QXQT ETC.DBES

INPUT DATA FOR DBE PRGOGRAM
DRY COIL

\$INPUT
SPRAY = F,TCHG = .77000000+002,TCASP = .55000000+002,TMIN = .30000000+002,DELTA = .10000000+001
\$END

95.0000
\$OUTPUT
CCLV = T,DAMPOA = 0
\$END

75.0000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

67.0000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

40.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

80.0000
\$OUTPUT
CCLV = T,DAMPOA = 0
\$END

74.0000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

50.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

53.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

55.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

55.5000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

55.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

57.0000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

55.5000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

55.0000
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

54.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

55.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

50.0000
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END



APPENDIX B. COMPUTER PROGRAM LISTING OF THE ENTHALPY ECONOMIZER
ALGORITHM (ETC1), AND SAMPLE INPUT AND OUTPUT

```

Q$Q$Q$*ETC(1).ETC1ALL(0)
1      C *****
2      C
3      C      ETC1 :   Enthalpy economizer algorithm
4      C                for building air handling systems
5      C
6      C      VERSION I   July 29, 1983 C.P.
7      C
8      C -----
9      C
10     C      CCLV   Logical variable for controlling a cooling
11     C                coil valve. CCLV=T when the valve is open and CCLV=F
12     C                when it is closed.
13     C
14     C      DAMPOA Integer variable for controlling dampers.
15     C                DAMPOA = 0 for admitting minimum outdoor air
16     C                = 1 for modulating dampers
17     C                = 2 for admitting maximum outdoor air
18     C
19     C      DELTA  Temperature difference of floating zone to minimize
20     C                the switching frequency of damper or coil valve opening
21     C
22     C      DEWPT  Logical variable. Set TRUE if outside and return air
23     C                dew points are measured. Set FALSE if outside and return
24     C                air relative humidities are measured.
25     C
26     C      DPOA   Dew point temperature of outside air           (F)      (C)
27     C
28     C      DPRA   Dew point temperature of return air            (F)      (C)
29     C
30     C      HOA    Enthalpy of outside air                        (Btu/Lb) (KJ/kg)
31     C
32     C      HRA    Enthalpy of return air                         (Btu/Lb) (KJ/kg)
33     C
34     C      METRIC Logical variable. Set TRUE if metric unit is used.
35     C                Set FALSE if English unit is employed.
36     C
37     C      PB     Barometric pressure                            (in.Hg) (Pa)
38     C
39     C      RHOA   Relative humidity of outdoor air                (percent)
40     C
41     C      RHRA   Relative humidity of return air                 (percent)
42     C
43     C      SPRAY  Logical variable indicating type of cooling coil,
44     C                SPRAY = T if system uses a sprayed coil or air washer,
45     C                SPRAY = F otherwise.
46     C
47     C      TCA    Measured cooling coil discharge air dry-bulb temperature
48     C
49     C      TCASP  Set point value of cooling coil discharge air dry-bulb
50     C                temperature
51     C
52     C      TMIN   Specified outside air dry bulb temperture below which
53     C                minimum outside air is admitted
54     C
55     C      TOA    Measured outdoor air dry-bulb temperature
56     C
57     C      TRA    Retrun air dry-bulb temperature

```

```

58      C *****
59      C
60      C
61      SUBROUTINE ETC1
62      INTEGER DAMPOA
63      LOGICAL CCLV,SPRAY,DEWPT,METRIC
64      COMMON /BK1/ TCA,TCASP,TMIN,SPRAY,DELTA
65      & /BK2/ DEWPT,METRIC
66      & /BK3/ CCLV,DAMPOA
67      & /BK4/ TOA,DPOA,RHOA,TRA,DPRA,RHRA,PB
68      NAMELIST /OUT1/ HOA,HRA
69      C
70      C      Enthalpy economizer
71      C
72      C      Compute enthalpies of outdoor and return air
73      C
74      CALL PSYCHR(TOA,DPOA,RHOA,PB,HOA)
75      CALL PSYCHR(TRA,DPRA,RHRA,PB,HRA)
76      C
77      C      Determine outdoor air damper opening and cooling coil valve
78      C      operation
79      C
80      IF(TOA.LE.TMIN) THEN
81          CCLV=.FALSE.
82          DAMPOA=0
83      ELSEIF(HOA.GE.HRA+DELTA) THEN
84          CCLV=.TRUE.
85          DAMPOA=0
86      ELSEIF(HOA.LE.HRA-DELTA) THEN
87          IF(SPRAY) THEN
88              IF(TCA.GE.TCASP+DELTA) THEN
89                  CCLV=.TRUE.
90                  DAMPOA=2
91              ELSEIF(TCA.LE.TCASP-DELTA) THEN
92                  CCLV=.FALSE.
93                  DAMPOA=1
94              ENDIF
95          ELSE
96              IF(TOA.GE.TRA+DELTA) THEN
97                  CCLV=.TRUE.
98                  DAMPOA=0
99              ELSEIF(TOA.LE.TRA-DELTA) THEN
100                  IF(TOA.GE.TCASP+DELTA) THEN
101                      CCLV=.TRUE.
102                      DAMPOA=2
103                  ELSEIF(TOA.LE.TCASP-DELTA) THEN
104                      CCLV=.FALSE.
105                      DAMPOA=1
106                  ENDIF
107              ENDIF
108          ENDIF
109      ENDIF
110      PRINT OUT1
111      C
112      RETURN
113      END
114      C *****
115      C

```

```

116 C      PSYCHR : Psychrometric properties of moist air between
117 C                60 F (15.6 C) and 140 F (60 C) with estimated error
118 C                of 0.02 %
119 C
120 C      Sources : ASHRAE 1981 Fundamentals Handbook, Chapter 5
121 C                ASHRAE Journal Jan. 1979 (R. S. Brokaw ) PP. 49-51
122 C

```

```

123 C -----
124 C
125 C                                     English      Metric
126 C                                     -----      -
127 C      DB      Dry-bulb air temperature      F          C
128 C      DP      Dew point temperature         F          C
129 C      H        Enthalpy                      Btu/Lb      KJ/kg
130 C      PB      Barometric pressure           in.Hg       Pa
131 C      PSW     Saturated water avpor pressure in.Hg       Pa
132 C      PW      Water vapor pressure          in.Hg       Pa
133 C      RH      Relative humidity             percent     percent
134 C      W        Humidity ratio                -          -
135 C

```

```

136 C *****
137 C

```

```

138 C      SUBROUTINE PSYCHR(DB,DP,RH,PB,H)
139 C      LOGICAL DEWPT,METRIC
140 C      COMMON /BK2/ DEWPT,METRIC

```

```

141 C
142 C      Dew point temp or relative humidity
143 C

```

```

144 C      IF(DEWPT) THEN
145 C          TEMP=DP
146 C          RH=100.0
147 C      ELSE
148 C          TEMP=DB
149 C      ENDIF

```

```

150 C
151 C      Compute psychrometric properties using metric units
152 C

```

```

153 C      IF(METRIC) THEN
154 C          PSW=3.37685E+3*EXP(15.4636-7284./((1.8*TEMP+424.)))
155 C          PW=RH/100.*PSW
156 C          W=0.62198*(PW/(PB-PW))
157 C          H=DB+W*(2501.+1.805*DB)
158 C          IF(.NOT.DEWPT) THEN
159 C              PWLOG=ALOG(PW)
160 C              DP=-35.957-1.8726*PWLOG+1.1689*PWLOG*PWLOG
161 C          ENDIF

```

```

162 C
163 C      Compute psychrometric properties using English units
164 C

```

```

165 C      ELSE
166 C          PSW=EXP(15.4636-7284./((TEMP+392.)))
167 C          PW=RH/100.*PSW
168 C          W=0.62198*(PW/(PB-PW))
169 C          H=0.24*DB+W*(1061.+0.444*DB)
170 C          IF(.NOT.DEWPT) THEN
171 C              PWLOG=ALOG(PW)
172 C              DP=79.047+30.5790*PWLOG+1.8893*PWLOG*PWLOG
173 C          ENDIF

```



```

174      ENDIF
175      C
176      C
177      RETURN
178      END
179      C *****
180      C
181      C      ETC1MAIN : Main program to call the enthalpy economizer
182      C                  algorithm for building air handling systems
183      C
184      C      VERSION I      July 29, 1983 C.P.
185      C
186      C      -----
187      C
188      C      TITLE      Title of the input data set
189      C      Y(I)      Input data array
190      C      Y(1) = PB
191      C      Y(2) = TOA
192      C      Y(3) = DPOA if DEWPT=T, RHOA if DEWPT=F
193      C      Y(4) = TRA
194      C      Y(5) = DPRA if DEWPT=T, RHRA if DEWPT=F
195      C      Y(6) = TCA
196      C *****
197      C
198      C
199      C      LOGICAL CCLV,SPRAY,DEWPT,METRIC
200      C      INTEGER DAMPOA
201      C      CHARACTER TITLE(2)*80
202      C      DIMENSION Y(6)
203      C      COMMON /BK1/ TCA,TCASP,TMIN,SPRAY,DELTA
204      C      & /BK2/ DEWPT,METRIC
205      C      & /BK3/ CCLV,DAMPOA
206      C      & /BK4/ TOA,DPOA,RHOA,TRA,DPRA,RHRA,PB
207      C      NAMELIST /INPUT/ METRIC,DEWPT,SPRAY,TCASP,TMIN,DELTA
208      C      & /OUTPUT/ CCLV,DAMPOA
209      C      OPEN(7,FILE='ETC1DATA')
210      C      REWIND 7
211      C
212      C      Read initial input data
213      C
214      C      READ(7,1000) TITLE
215      C      READ(7,INPUT)
216      C      PRINT 1000,TITLE
217      C      PRINT INPUT
218      C
219      C      IF (SPRAY) THEN
220      C          N=6
221      C      ELSE
222      C          N=5
223      C      ENDIF
224      C
225      C      Read measured input data
226      C
227      C      10 READ(7,*,END=999) (Y(I),I=1,N)
228      C      PRINT 2000,(Y(I),I=1,N)
229      C      PB =Y(1)
230      C      TOA=Y(2)
231      C      TRA=Y(4)

```

```

232      TCA=Y(6)
233      C
234      C      Dew point temp or relative humidity
235      C
236      IF(DEWPT) THEN
237          RHOA=100.0
238          RHRA=100.0
239          DPOA=Y(3)
240          DPRA=Y(5)
241      ELSE
242          DPOA=0.0
243          DPRA=0.0
244          RHOA=Y(3)
245          RHRA=Y(5)
246      ENDIF
247      C
248      C      Call the enthalpy control algorithm
249      C
250      CALL ETC1
251      C
252      PRINT OUTPUT
253      PRINT 3000
254      C
255      C      Damper and cooling coil valve control routines should be
256      C      called here. These routines are machine-dependent.
257      C
258      GOTO 10
259      C
260      C      Format statements
261      C
262      1000  FORMAT(A80/A80)
263      2000  FORMAT(8F10.4)
264      3000  FORMAT(1X,79('-','))
265      C
266      999  STOP
267      END

```

QSQSQ\$*ETC1DATA(1)

```
1      INPUT DATA FOR ETC1 PROGRAM
2      DRY COIL
3      $INPUT METRIC=F,DEWPT=T,SPRAY=F,TCASP=55.0,TMIN=30.0,DELTA=1.0,$END
4      29.921 95.0 60.0 77.0 55.0
5      29.921 75.0 64.0 77.0 55.0
6      29.921 67.0 57.0 77.0 55.0
7      29.921 40.0 35.0 77.0 55.0
8      29.921 80.0 57.0 77.0 55.0
9      29.921 74.0 51.0 77.0 55.0
10     29.921 50.0 40.0 77.0 55.0
11     29.921 53.0 40.0 77.0 55.0
12     29.921 55.0 40.0 77.0 55.0
13     29.921 55.5 40.0 77.0 55.0
14     29.921 55.0 40.0 77.0 55.0
15     29.921 57.0 40.0 77.0 55.0
16     29.921 55.5 40.0 77.0 55.0
17     29.921 55.0 40.0 77.0 55.0
18     29.921 54.0 40.0 77.0 55.0
19     29.921 55.0 40.0 77.0 55.0
20     29.921 50.0 40.0 77.0 55.0
```

QXQT ETC.ETC1\$

INPUT DATA FOR ETC1 PROGRAM
DRY COIL

\$INPUT
METRIC = F,DEWPT = T,SPRAY = F,TCASP = .55000000+002,TMIN = .30000000+002,DELTA = .10000000+001
\$END

29.9210 95.0000 60.0000 77.0000 55.0000

\$OUT1
HOA = .34966373+002,HRA = .28536576+002
\$END

\$OUTPUT
CCLV = T,DAMPOA = 0
\$END

29.9210 75.0000 64.0000 77.0000 55.0000

\$OUT1
HOA = .31938431+002,HRA = .28536576+002
\$END

\$OUTPUT
CCLV = T,DAMPOA = 0
\$END

29.9210 67.0000 57.0000 77.0000 55.0000

\$OUT1
HOA = .26861820+002,HRA = .28536576+002
\$END

\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

29.9210 40.0000 35.0000 77.0000 55.0000

\$OUT1
HOA = .14181454+002,HRA = .28536576+002
\$END
\$OUTPUT

CCLV = F,DAMPOA = 1
\$END

29.9210 80.0000 57.0000 77.0000 55.0000
\$OUT1
HOA = .30038875+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = T,DAMPOA = 0
\$END

29.9210 74.0000 51.0000 77.0000 55.0000
\$OUT1
HOA = .26412566+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = T,DAMPOA = 2
\$END

29.9210 50.0000 40.0000 77.0000 55.0000
\$OUT1
HOA = .17612815+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

29.9210 53.0000 40.0000 77.0000 55.0000
\$OUT1
HOA = .18339717+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

29.9210 55.0000 40.0000 77.0000 55.0000
\$OUT1
HOA = .18824318+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

29.9210 55.5000 40.0000 77.0000 55.0000
\$OUT1
HOA = .18945469+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

29.9210 55.0000 40.0000 77.0000 55.0000
\$OUT1
HOA = .18824318+002,HRA = .28536576+002
\$END
\$OUTPUT
CCLV = F,DAMPOA = 1
\$END

29.9210 57.0000 40.0000 77.0000 55.0000

\$OUT1

HOA = .19308920+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = T, DAMPOA = 2

\$END

29.9210 55.5000 40.0000 77.0000 55.0000

\$OUT1

HOA = .18945469+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = T, DAMPOA = 2

\$END

29.9210 55.0000 40.0000 77.0000 55.0000

\$OUT1

HOA = .18824318+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = T, DAMPOA = 2

\$END

29.9210 54.0000 40.0000 77.0000 55.0000

\$OUT1

HOA = .18582018+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = F, DAMPOA = 1

\$END

29.9210 55.0000 40.0000 77.0000 55.0000

\$OUT1

HOA = .18824318+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = F, DAMPOA = 1

\$END

29.9210 50.0000 40.0000 77.0000 55.0000

\$OUT1

HOA = .17612815+002, HRA = .28536576+002

\$END

\$OUTPUT

CCLV = F, DAMPOA = 1

\$END

APPENDIX C. DERIVATION OF THE DIMENSIONLESS FACTOR, λ

For dual-duct and multi-zone systems, the basic enthalpy economizer algorithm described in section 6 is modified to take into account the differences in the costs of heating energy and cooling energy. This is discussed in sections 7 and 8. A dimensionless factor, λ , is introduced as the ratio of the total energy cost (cooling and heating) of the air-handling system with the outside air damper at the minimum opening position to that with the damper at the maximum opening position. The derivation of λ is presented here (see figures 5 and 14).

Energy equations for the system shown in figure 5 are as follows:

$$m_{OA} h_{OA} + m_{RA} h_{RA} = m_{MA} h_{MA} \quad (1)$$

$$m_{MA} h_{MA} + q_F = m_{SA} h_{SA} \quad (2)$$

$$m_{HA} h_{SA} + q_H = m_{HA} h_{HA} \quad (3)$$

$$m_{CA} h_{SA} + q_C = m_{CA} h_{CA} \quad (4)$$

where m , h , and q represent mass flow rate, enthalpy, and heat flow rate, respectively.

Subscripts are:

OA: outdoor air

RA: return air

MA: mixed air

CA: the air leaving the cooling coil

HA: the air leaving the heating coil

SA: supply air

C: cooling coil

H: heating coil

F: supply fan

Assume that q_F is negligible ($q_F \approx 0$), and that the mass of added or removed moisture is negligible with respect to air mass. Applying the mass conservation principle, heat flow rates for heating and cooling can be expressed, from equations (1) through (4), as:

$$q_H = m_{HA} h_{HA} - (m_{HA}/m_{SA})(m_{OA} h_{OA} + m_{RA} h_{RA}) \quad (5)$$

$$q_C = m_{CA} h_{CA} - (m_{CA}/m_{SA})(m_{OA} h_{OA} + m_{RA} h_{RA}) \quad (6)$$

When the outside air damper is positioned to admit the minimum amount of outdoor air,

$$m_{RA} = m_{SA} - m_{OA,min} \quad (7)$$

$$m_{OA} = m_{OA,min} \quad (8)$$

where $m_{OA,min}$ is the mass flow rate of the outside air with its damper at the minimum opening position.

When the outside air damper is positioned at its maximum opening,

$$m_{RA} = 0 \quad (9)$$

$$m_{OA} = m_{SA} \quad (10)$$

Substituting equations (7) and (8) into (5) and (6), we obtain:

$$q_{H,min} = m_{HA} h_{HA} - (m_{HA}/m_{SA}) \left[m_{OA,min} h_{OA} + (m_{SA} - m_{OA,min}) h_{RA} \right] \quad (11)$$

$$q_{C,min} = m_{CA} h_{CA} - (m_{CA}/m_{SA}) \left[m_{OA,min} h_{OA} + (m_{SA} - m_{OA,min}) h_{RA} \right] \quad (12)$$

Similarly, with the damper at maximum position, the heat flow rate equations become:

$$q_{H,max} = m_{HA} (h_{HA} - h_{OA}) \quad (13)$$

$$q_{C,max} = m_{CA} (h_{CA} - h_{OA}) \quad (14)$$

We can normalize equations (11) through (14) by m_{SA} . From equations (11) and (12), we have

$$q'_{H,min} = x_{HA} h_{HA} - x_{HA} \left[x_{OA,min} h_{OA} + (1 - x_{OA,min}) h_{RA} \right] \quad (15)$$

$$q'_{C,min} = x_{CA} h_{CA} - x_{CA} \left[x_{OA,min} h_{OA} + (1 - x_{OA,min}) h_{RA} \right] \quad (16)$$

where x_{HA} = the ratio of heating coil air mass flow rate to supply air mass flow rate

x_{CA} = the ratio of cooling coil air volumetric flow rate to supply air mass flow rate

$x_{OA,min}$ = the ratio of minimum outdoor air mass flow rate to supply air mass flow rate

Assume that density variation due to temperature differences is negligible, then x_{HA} , x_{CA} , and $x_{OA,min}$ can be volumetric flow rate ratios instead of mass flow ratios.

Equations (13) and (14) yield:

$$q'_{H,max} = x_{HA} (h_{HA} - h_{OA}) \quad (17)$$

$$q'_{C,max} = x_{CA} (h_{CA} - h_{OA}) \quad (18)$$

Defining β as a unit energy cost ratio in terms of dollars of heating to cooling, the dimensionless factor, λ , can be expressed as:

$$\lambda = \frac{(\beta q'_{H,min}) + (-q'_{C,min})}{(\beta q'_{H,max}) + (-q'_{C,max})} \quad (19)$$

In equation (19), $q'_{H,min}$ and $q'_{H,max}$ should be zero or positive, and $q'_{C,min}$ and $q'_{C,max}$ should be zero or negative. As a result, λ is always positive and can be used as a criteria to decide the outside air damper position. When λ is greater than 1, it is more economical to have the maximum amount of outside air entering the system than the minimum amount of outside air. Therefore, the outside air damper should be opened fully. Otherwise, it should be at its minimum opening position.

APPENDIX D. COMPUTER PROGRAM LISTING OF THE ENTHALPY ECONOMIZER
ALGORITHM WITH ENHANCEMENT (ETC2), AND SAMPLE INPUT
AND OUTPUT

```

Q$Q$Q$*ETC(1).ETC2ALL(0)
1      C *****
2      C
3      C
4      C      ETC2 :   Enhanced enthalpy economizer algorithm
5      C              for building air handling systems
6      C      --- The enhancement is applicable to a dual-duct system. ----
7      C      VERSION II   July 29, 1983 C.P.
8      C
9      C      -----
10     C
11     C      CCLV   Logical variable for controlling a cooling
12     C              coil valve. CCLV=T when the valve is open and CCLV=F
13     C              when it is closed.
14     C
15     C      COST   Logical variable for economical cost analysis in
16     C              determining the damper opening. Set TRUE if
17     C              the cost analysis routine is desired. FALSE otherwise.
18     C              Only dual-duct systems are applicable in cost analysis.
19     C
20     C      DAMPOA Integer variable for controlling dampers.
21     C              DAMPOA = 0 for admitting minimum outdoor air
22     C              = 1 for modulating dampers
23     C              = 2 for admitting maximum outdoor air
24     C
25     C      DELTA   Temperature difference of floating zone to minimize
26     C              the switching frequency of damper or coil valve opening
27     C
28     C      DEWPT   Logical variable. Set TRUE if outside and return air
29     C              dew points are measured. Set FALSE if outside and return
30     C              air relative humidities are measured.
31     C
32     C      DPOA   Dew point temperature of outside air      (F)      (C)
33     C
34     C      DPRA   Dew point temperature of return air      (F)      (C)
35     C
36     C      HOA    Enthalpy of outside air                  (Btu/Lb) (KJ/kg)
37     C
38     C      HRA    Enthalpy of return air                    (Btu/Lb) (KJ/kg)
39     C
40     C      METRIC Logical variable. Set TRUE if metric unit is used.
41     C              Set FALSE if English unit is employed.
42     C
43     C      PB     Barometric pressure                      (in.Hg) (Pa)
44     C
45     C      RHOA   Relative humidity of outdoor air          (percent)
46     C
47     C      RHRA   Relative humidity of return air           (percent)
48     C
49     C      SPRAY  Logical variable indicating type of cooling coil,
50     C              SPRAY = T if system uses a sprayed coil or air washer,
51     C              SPRAY = F otherwise.
52     C
53     C      TCA    Measured cooling coil discharge air dry-bulb temperature
54     C
55     C      TCASP  Set point value of cooling coil discharge air dry-bulb
56     C              temperature
57     C

```

```

58      C      TMIN   Specified outside air dry bulb temperature below which
59      C          minimum outside air is admitted
60      C
61      C      TOA    Measured outdoor air dry-bulb temperature
62      C
63      C      TRA    Retrun air dry-bulb temperature
64      C
65      C *****
66      C
67      SUBROUTINE ETC2
68      INTEGER DAMPOA
69      LOGICAL CCLV, SPRAY, DEWPT, METRIC, COST
70      COMMON /BK1/ COST, TCA, TCASP, TMIN, SPRAY, DELTA
71      &      /BK2/ DEWPT, METRIC
72      &      /BK3/ CCLV, DAMPOA
73      &      /BK4/ TOA, DPOA, RHOA, TRA, DPRA, RHRA, PB
74      NAMELIST /OUT1/ HOA, HRA
75      C
76      C      Enthalpy economizer
77      C
78      C      Compute enthalpies of outdoor and return air
79      C
80      CALL PSYCHR(TOA, DPOA, RHOA, PB, HOA)
81      CALL PSYCHR(TRA, DPRA, RHRA, PB, HRA)
82      C
83      C      Determine outdoor air damper opening and cooling coil valve
84      C      operation
85      C
86      IF(TOA.LE.TMIN) THEN
87          CCLV=.FALSE.
88          DAMPOA=0
89      ELSEIF(HOA.GE.HRA+DELTA) THEN
90          CCLV=.TRUE.
91          DAMPOA=0
92      ELSEIF(HOA.LE.HRA-DELTA) THEN
93          IF(SPRAY) THEN
94              IF(TCA.GE.TCASP+DELTA) THEN
95                  CCLV=.TRUE.
96                  DAMPOA=2
97              ELSEIF(TCA.LE.TCASP-DELTA) THEN
98                  CCLV=.FALSE.
99                  DAMPOA=1
100          ENDIF
101      ELSE
102          IF(TOA.GE.TRA+DELTA) THEN
103              CCLV=.TRUE.
104              DAMPOA=0
105          ELSEIF(TOA.LE.TRA-DELTA) THEN
106              IF(TOA.GE.TCASP+DELTA) THEN
107                  CCLV=.TRUE.
108                  DAMPOA=2
109              ELSEIF(TOA.LE.TCASP-DELTA) THEN
110                  CCLV=.FALSE.
111                  DAMPOA=1
112          ENDIF
113      ENDIF
114      ENDIF
115      ENDIF

```

```

116      PRINT OUT1
117      C
118      C      At this point, the outdoor air damper opening can be changed
119      C      from maximum to minimum, and vice versa depending on the result
120      C      of the cost analysis. This cost analysis is only recommended
121      C      to a dual-duct system.
122      C
123      IF(COST.AND.CCLV.AND.(DAMPOA.EQ.0 .OR. DAMPOA.EQ.2)) THEN
124          CALL HCCOST
125          PRINT OUT1
126      ENDIF
127      C
128      RETURN
129      END
130      C *****
131      C
132      C      PSYCHR : Psychrometric properties of moist air between
133      C      60 F (15.6 C) and 140 F (60 C) with estimated error
134      C      of 0.02 %
135      C
136      C      Sources : ASHRAE 1981 Fundamentals Handbook, Chapter 5
137      C      ASHRAE Journal Jan. 1979 (R. S. Brokaw ) PP. 49-51
138      C
139      C -----
140      C
141      C
142      C
143      C      DB      Dry-bulb air temperature      F      C
144      C      DP      Dew point temperature        F      C
145      C      H      Enthalpy                      Btu/Lb  KJ/kg
146      C      PB      Barometric pressure          in.Hg   Pa
147      C      PSW     Saturated water avpor pressure in.Hg   Pa
148      C      PW      Water vapor pressure         in.Hg   Pa
149      C      RH      Relative humidity            percent percent
150      C      W      Humidity ratio                -      -
151      C
152      C *****
153      C
154      C      SUBROUTINE PSYCHR(DB,DP,RH,PB,H)
155      C      LOGICAL DEWPT,METRIC
156      C      COMMON /BK2/ DEWPT,METRIC
157      C
158      C      Dew point temp or relative humidity
159      C
160      C      IF(DEWPT) THEN
161      C          TEMP=DP
162      C          RH=100.0
163      C      ELSE
164      C          TEMP=DB
165      C      ENDIF
166      C
167      C      Compute psychrometric properties using metric units
168      C
169      C      IF(METRIC) THEN
170      C          PSW=3.37685E+3*EXP(15.4636-7284./(1.8*TEMP+424.))
171      C          PW=RH/100.*PSW
172      C          W=0.62198*(PW/(PB-PW))
173      C          H=DB+W*(2501.+1.805*DB)

```

```

174             IF(.NOT.DEWPT) THEN
175                 PWLOG=ALOG(PW)
176                 DP=-35.957-1.8726*PWLOG+1.1689*PWLOG*PWLOG
177             ENDIF
178         C
179         C      Compute psychrometric properties using English units
180         C
181         ELSE
182             PSW=EXP(15.4636-7284./(TEMP+392.))
183             PW=RH/100.*PSW
184             W=0.62198*(PW/(PB-PW))
185             H=0.24*DB+W*(1061.+0.444*DB)
186             IF(.NOT.DEWPT) THEN
187                 PWLOG=ALOG(PW)
188                 DP=79.047+30.5790*PWLOG+1.8893*PWLOG*PWLOG
189             ENDIF
190         ENDIF
191         C
192         C
193         RETURN
194         END
195         C *****
196         C
197         C      HCCOST : Outside air damper opening based upon the economic
198         C                  decision on heating and cooling costs for dual duct
199         C                  systems
200         C
201         C      July 29, 1983 C.P.
202         C
203         C -----
204         C
205         C      DPCA   Measured dew point of cooling coil discharge air
206         C
207         C      DPHA   Measured dew point of heating coil discharge air
208         C
209         C      HCA    Enthalpy of cooling coil discharge air
210         C
211         C      HGTOCL Unit energy cost ratio in terms of dollars of
212         C                  heating to cooling
213         C                  =($ of heating per Btu or KJ)/($ of cooling per Btu or
214         C                  KJ)
215         C
216         C      HHA    Enthalpy of heating coil discharge air
217         C
218         C      LAMMDA Real variable indicating the ratio of the cost with
219         C                  minimum damper opening to that with maximum damper
220         C                  opening.
221         C
222         C      RHCA   Relative humidity in percent of cooling coil discharge air
223         C
224         C      RHHA   Relative humidity in percent of heating coil discharge air
225         C
226         C      TCA    Dry-bulb temp. of cooling coil discharge air
227         C
228         C      THA    Dry-bulb temp. of heating coil discharge air
229         C
230         C      XCA    Ratio of cooling coil discharge air flow rate to supply
231         C                  air flow rate

```



```

232 C
233 C      XHA      Ratio of heating coil discharge air flow rate to supply
234 C              air flow rate
235 C
236 C      XOAMIN   Ratio of outside air flow rate thru the minimum damper
237 C              opening for fresh air requirement to supply air flow rate
238 C
239 C      ----- Either metric or English unit can be used. -----
240 C
241 C      ****
242 C
243 C      SUBROUTINE HCCOST
244 C              LOGICAL CCLV,SPRAY,COST
245 C              INTEGER DAMPOA
246 C              REAL LAMMDA
247 C              COMMON /BK1/ COST,TCA,TCASP,TMIN,SPRAY,DELTA
248 C              &      /BK3/ CCLV,DAMPOA
249 C              &      /BK4/ TOA,DPOA,RHOA,TRA,DPRA,RHRA,PB
250 C              &      /BK5/ HGTOCL,DPCA,RHCA,THA,DPHA,RHHA,XOAMIN,XCA,XHA
251 C
252 C      Compute enthalpies
253 C
254 C      CALL PSYCHR(TOA,DPOA,RHOA,PB,HOA)
255 C      CALL PSYCHR(TRA,DPRA,RHRA,PB,HRA)
256 C      CALL PSYCHR(TCA,DPCA,RHCA,PB,HCA)
257 C      CALL PSYCHR(THA,DPHA,RHHA,PB,HHA)
258 C
259 C      Compute the ratio of the cost with minimum damper
260 C      opening to the cost with maximum damper opening
261 C
262 C      QHMIN=XHA*HHA-XHA*(XOAMIN*HOA+(1-XOAMIN)*HRA)
263 C      QCMIN=XCA*HCA-XCA*(XOAMIN*HOA+(1-XOAMIN)*HRA)
264 C      QHMAX=XHA*(HHA-HOA)
265 C      QCMAX=XCA*(HCA-HOA)
266 C
267 C      IF(QHMIN.LT.0) QHMIN=0
268 C      IF(QHMAX.LT.0) QHMAX=0
269 C      IF(QCMIN.GT.0) QCMIN=0
270 C      IF(QCMAX.GT.0) QCMAX=0
271 C
272 C      CMIN=HGTOCL*QHMIN-QCMIN
273 C      CMAX=HGTOCL*QHMAX-QCMAX
274 C      IF(CMAX.GT.0 .AND. CMIN.GT. 0) THEN
275 C          LAMMDA=CMIN/CMAX
276 C      ENDIF
277 C
278 C      IF(LAMMDA.GT.1.0) THEN
279 C          DAMPOA=2
280 C      ELSE
281 C          DAMPOA=0
282 C      ENDIF
283 C      PRINT 1000,LAMMDA
284 C
285 C      1000 FORMAT(/5X,'COST EVALUATION HAS BEEN MADE ---'/
286 C      & 5X,'LAMMDA = ',F10.4/)
287 C
288 C      RETURN
289 C      END

```



```

290 C *****
291 C
292 C      ETC2MAIN : Main program to call the enhanced version of the
293 C                enthalpy economizer algorithm for building air
294 C                handling systems
295 C      ---- The enhancement is applicable to a dual-duct systems. ---
296 C
297 C      VERSION II July 29, 1983 C.P.
298 C
299 C -----
300 C
301 C      TITLE Title of the input data set
302 C      Y(I) Input data array
303 C            Y(1) = PB
304 C            Y(2) = TOA
305 C            Y(3) = DPOA if DEWPT=T, RHOA if DEWPT=F
306 C            Y(4) = TRA
307 C            Y(5) = DPRA if DEWPT=T, RHRA if DEWPT=F
308 C            Y(6) = TCA
309 C            Y(7) = DPCA if DEWPT=T, RHCA if DEWPT=F
310 C            Y(8) = THA
311 C            Y(9) = DPHA if DEWPT=T, RHHA if DEWPT=F
312 C            Y(10) = XCA
313 C            Y(11) = XHA
314 C
315 C *****
316 C
317 C
318 C      LOGICAL CCLV,SPRAY,DEWPT,METRIC,COST
319 C      CHARACTER TITLE(2)*80
320 C      INTEGER DAMPOA
321 C      DIMENSION Y(11)
322 C      COMMON /BK1/ COST,TCA,TCASP,TMIN,SPRAY,DELTA
323 C      & /BK2/ DEWPT,METRIC
324 C      & /BK3/ CCLV,DAMPOA
325 C      & /BK4/ TOA,DPOA,RHOA,TRA,DPRA,RHRA,PB
326 C      & /BK5/ HGTOCL,DPCA,RHCA,THA,DPHA,RHHA,XOAMIN,XCA,XHA
327 C      NAMELIST /INPUT/ METRIC,DEWPT,SPRAY,TCASP,TMIN,DELTA,COST
328 C      & /OUTPUT/ CCLV,DAMPOA
329 C      & /HCIN/ HGTOCL,XOAMIN
330 C      OPEN(7,FILE='ETC2DATA')
331 C      REWIND 7
332 C
333 C      Read initial input data
334 C
335 C      READ(7,1000) TITLE
336 C      READ(7,INPUT)
337 C      PRINT 1000,TITLE
338 C      PRINT INPUT
339 C      IF(COST) THEN
340 C          READ(7,HCIN)
341 C          PRINT HCIN
342 C          N=11
343 C      ELSEIF(SPRAY) THEN
344 C          N=6
345 C      ELSE
346 C          N=5
347 C      ENDIF

```

```

348      C
349      C      READ MEASURED INPUT DATA
350      C
351      10      READ(7,*,END=999) (Y(I),I=1,N)
352      PRINT 2000,(Y(I),I=1,N)
353      PB=Y(1)
354      TOA=Y(2)
355      TRA=Y(4)
356      TCA=Y(6)
357      THA=Y(8)
358      XCA=Y(10)
359      XHA=Y(11)
360
361      C
362      C      Dew point temperature or relative humidity
363      C
364      IF(DEWPT) THEN
365          RHOA=100.0
366          RHRA=100.0
367          RHCA=100.0
368          RHHA=100.0
369          DPOA=Y(3)
370          DPRA=Y(5)
371          DPCA=Y(7)
372          DPHA=Y(9)
373      ELSE
374          DPOA=0.0
375          DPRA=0.0
376          DPCA=0.0
377          DPHA=0.0
378          RHOA=Y(3)
379          RHRA=Y(5)
380          RHCA=Y(7)
381          RHHA=Y(9)
382      ENDIF
383
384      C
385      C      Call the enthalpy economizer algorithm
386      CALL ETC2
387
388      C
389      PRINT OUTPUT
390      PRINT 3000
391
392      C
393      C      Damper and coil valve control routines should be
394      C      called here. These routines are machine-dependent.
395      GOTO 10
396
397      C
398      C      FORMAT STATEMENTS
399      1000      FORMAT(A80/A80)
400      2000      FORMAT(8F10.4)
401      3000      FORMAT(1X,79('-','))
402      C
403      999      STOP
404      END

```

```

Q$Q$Q$*ETC2DATA(1)
1      INPUT DATA FOR ETC2 PROGRAM
2      DRY COIL WITHOUT COST EVALUATION
3      $INPUT METRIC=F,DEWPT=T,SPRAY=F,TCASP=55.0,TMIN=30.0,DELTA=1.0,COST=F,$END
4      29.921 85.0 40.0 77.0 60.0 55.0
5      29.921 56.0 50.0 77.0 55.0 55.0
6      29.921 65.0 50.0 77.0 55.0 55.0
7      29.921 90.0 65.0 77.0 60.0 55.0
8      29.921 50.0 40.0 77.0 60.0 55.0

@XQT ETC.ETC2$
INPUT DATA FOR ETC2 PROGRAM
DRY COIL WITHOUT COST EVALUATION
$INPUT
METRIC = F,DEWPT = T,SPRAY = F,TCASP = .55000000+002,TMIN = .30000000+002,DELTA = .10000000+001,COST = F
$END
$OUT1
29.9210 85.0000 40.0000 77.0000 60.0000
HOA = .26093338+002,HRA = .30558234+002
$END
$OUTPUT
CCLV = T,DAMPOA = 0
$END
-----
29.9210 56.0000 50.0000 77.0000 55.0000
$OUT1
HOA = .21711853+002,HRA = .28536576+002
$END
$OUTPUT
CCLV = T,DAMPOA = 2
$END
-----
29.9210 65.0000 50.0000 77.0000 55.0000
$OUT1
HOA = .23902294+002,HRA = .28536576+002
$END
$OUTPUT
CCLV = T,DAMPOA = 2
$END
-----
29.9210 90.0000 65.0000 77.0000 60.0000
$OUT1
HOA = .36132675+002,HRA = .30558234+002
$END
$OUTPUT
CCLV = T,DAMPOA = 0
$END
-----
29.9210 50.0000 40.0000 77.0000 60.0000
$OUT1
HOA = .17612815+002,HRA = .30558234+002
$END
$OUTPUT
CCLV = F,DAMPOA = 1
$END
-----

```

```

Q$Q$Q$*ETC2DATA(1)
1 INPUT DATA FOR ETC2 PROGRAM
2 DRY COIL WITH COST EVALUATION
3 INPUT METRIC=F,DEWPT=T,SPRAY=F,TCASP=55.0,TMIN=30.0,DELTA=1.0,COST=T,$END
4 $HCIN HGTOCL=0.69,XOAMIN=0.1,$END
5 29.921 85.0 40.0 77.0 60.0 55.0 54.0 90.0 55.0 .25 .75
6 29.921 56.0 50.0 77.0 55.0 55.0 54.0 100.0 50.0 .25 .75
7 29.921 65.0 50.0 77.0 55.0 55.0 54.0 100.0 50.0 .25 .75
8 29.921 90.0 65.0 77.0 60.0 55.0 54.0 90.0 55.0 .25 .75
9 29.921 50.0 40.0 77.0 60.0 55.0 54.0 90.0 55.0 .25 .75

```

```

QXQT ETC.ETC2$
INPUT DATA FOR ETC2 PROGRAM
DRY COIL WITH COST EVALUATION
$INPUT
METRIC = F,DEWPT = T,SPRAY = F,TCASP = .55000000+002,TMIN = .30000000+002,DELTA = .10000000+001,COST = T
$END
$HCIN
HGTOCL = .69000000+000,XOAMIN = .10000000+000
$END
29.9210 85.0000 40.0000 77.0000 60.0000 55.0000 54.0000 90.0000
55.0000 .2500 .7500
SOUT1
HOA = .26093338+002,HRA = .30558234+002
$END

```

COST EVALUATION HAS BEEN MADE ---
LAMMDA = .7117

```

SOUT1
HOA = .26093338+002,HRA = .30558234+002
$END
$OUTPUT
CCLV = T,DAMPOA = 0
$END
-----
29.9210 56.0000 50.0000 77.0000 55.0000 55.0000 54.0000 100.0000
50.0000 .2500 .7500
SOUT1
HOA = .21711853+002,HRA = .28536576+002
$END

```

COST EVALUATION HAS BEEN MADE ---
LAMMDA = .6542

```

SOUT1
HOA = .21711853+002,HRA = .28536576+002
$END
$OUTPUT
CCLV = T,DAMPOA = 0
$END
-----
29.9210 65.0000 50.0000 77.0000 55.0000 55.0000 54.0000 100.0000
50.0000 .2500 .7500
SOUT1
HOA = .23902294+002,HRA = .28536576+002
$END

```

COST EVALUATION HAS BEEN MADE ---
LAMMDA = .7617

\$OUT1
HOA = .23902294+002, HRA = .28536576+002
\$END
\$OUTPUT
CCLV = T, DAMPOA = 0
\$END

29.9210 90.0000 65.0000 77.0000 54.0000 90.0000
55.0000 .2500 .7500
\$OUT1
HOA = .36132675+002, HRA = .30558234+002
\$END

COST EVALUATION HAS BEEN MADE ---
LAMMDA = .7158

\$OUT1
HOA = .36132675+002, HRA = .30558234+002
\$END
\$OUTPUT
CCLV = T, DAMPOA = 0
\$END

29.9210 50.0000 40.0000 77.0000 55.0000 54.0000 90.0000
55.0000 .2500 .7500
\$OUT1
HOA = .17612815+002, HRA = .30558234+002
\$END
\$OUTPUT
CCLV = F, DAMPOA = 1
\$END

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET (See instructions)		1. PUBLICATION OR REPORT NO. NBSIR 84-2832	2. Performing Organ. Report No.	3. Publication Date MARCH 1984
4. TITLE AND SUBTITLE Economizer Algorithms for Energy Management and Control Systems				
5. AUTHOR(S) Cheol Park, George E. Kelly, and James Y. Kao				
6. PERFORMING ORGANIZATION (If joint or other than NBS, see instructions) NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234			7. Contract/Grant No.	
			8. Type of Report & Period Covered	
9. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Office of Buildings & Community Systems U.S. Navy Civil Engineering Laboratory U.S. Department of Energy U.S. Department of Defense 1000 Independence Avenue, SW Washington, DC 20310 Washington, DC 20585				
10. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.				
11. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here) Economizer cycles have been recognized as important energy conservation measures for building air handling systems and have been included in most Energy Management and Control Systems (EMCS). This report describes the psychrometric processes of the most commonly used economizer cycles and presents algorithms for implementing these cycles on a typical Energy Management and Control System. Economizer cycles included in this study are dry-bulb and enthalpy types, as applied to both dry coils and sprayed coils. In addition, an enhancement to the normal enthalpy economizer cycle algorithm is presented for dual-duct or multi-zone system which takes into account differences in the costs of heating energy and cooling energy. Computer program listings of the algorithms and sample input/output data are shown in the appendices. A brief discussion of common types of air handling systems is also given to help the reader better understand the application of the algorithms presented in this report.				
12. KEY WORDS (Six to twelve entries; alphabetical order; capitalize only proper names; and separate key words by semicolons) control strategies; cooling energy; dry-bulb economizer cycle; energy management and control system; enthalpy economizer cycle; heating energy.				
13. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. <input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161			14. NO. OF PRINTED PAGES 81 15. Price \$11.50	

